

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION

(1) County Putnam



(3) DEC Well Number

P1602

(2) Township Putnam Valley

WELL COMPLETION REPORT



(4) OWNER VS Construction			LOG *		
(5) ADDRESS 37 Croton Dam Road, Ossining, NY 10562			Ground Surface EL. _____ ft. above sea level		
(6) LOCATION OF WELL (See Instructions On Reverse) Show Lat/Long if available and method used: <u>Kramers Pond Rd, Lot 7, Put-Chase Subd., Put.Valley</u> <input type="checkbox"/> GPS <input type="checkbox"/> DEC Website <input type="checkbox"/> Map Interpolation			Top Of Casing is located <u>+1</u> ft. above (+) or below (-) ground surface		
(7) DEPTH OF WELL BELOW LAND SURFACE (Feet) <u>645'</u>		(8) DEPTH TO GROUNDWATER BELOW LAND SURFACE (Feet) <u>N/A</u>		DATE MEASURED	
<b>CASINGS</b>					
(9) DIAMETER in.           in.					
(10) LENGTH ft.           in.					
(11) GROUT TYPE / SEALING			(12) GROUT / SEALING INTERVAL (Feet) FROM _____ TO _____		
<b>SCREENS</b>					
(13) MAKE & MATERIAL			(14) OPENINGS		
(15) DIAMETER in.           in.					
(16) LENGTH ft.           in.					
(17) DEPTH TO TOP OF SCREEN, FROM TOP OF CASING (Feet)					
<b>YIELD TEST</b>					
(18) DATE <u>3/30/01</u>			(19) DURATION OF TEST <u>6 hours</u>		
(20) LIFT METHOD <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift <input type="checkbox"/> Bail			(21) STABILIZED DISCHARGE (GPM) <u>7gpm</u>		
(22) STATIC LEVEL PRIOR TO TEST (feet/inches below top of casing) <u>30'</u>			(23) MAXIMUM DRAWDOWN (Stabilized) (feet/inches below top of casing) <u>580'</u>		
(24) RECOVERY (Time in hours/minutes) <u>140 minutes</u>			(25) Was the water produced during test discharged away from immediate area? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
<b>PUMP INSTALLATION</b>					
(26) PUMP INSTALLED? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		(27) DATE <u>3/30/01</u>		(28) PUMP INSTALLER <u>P. F. Beal &amp; Sons, Inc.</u>	
(29) TYPE <u>submersible</u>		(30) MAKE <u>Goulds</u>		(31) MODEL <u>7GS20412</u>	
(32) MAXIMUM CAPACITY (GPM) <u>7-8 gpm</u>		(33) PUMP INSTALLATION LEVEL FROM TOP OF CASING (Foot) <u>600'</u>			
(34) METHOD OF DRILLING <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Cable Tool <input type="checkbox"/> Other _____			(35) USE OF WATER (see instructions for choices) <u>residential</u>		
(36) DATE DRILLING WORK STARTED <u>2/8/01</u>			(37) DATE DRILLING WORK COMPLETED <u>2/11/01</u>		
(38) DATE REPORT FILED <u>4/19/01</u>		(39) DRILLER & COMPANY <u>Perry L. Beal P. F. Beal &amp; Sons, Inc.</u>		(40) DEC REGISTRATION NO. <u>NYRD10105</u>	
* Show log of geologic materials encountered with depth below ground surface, water bearing beds and water levels in each; casings; screens; pump; additional pumping tests and other matters of interest, e.g., water quality (sulphur, salt, methane). Describe repair work. Attach separate sheet if necessary.					
See further instructions titled "Instructions for New York State Well Completion Report".					
			645' _____		
BOTTOM OF HOLE					
<b>OWNER COPY</b>					

Drilled existing well deeper from 145' to 645'

Drilling in rock granite

Target is 41° 21' 31"N, 73° 51' 19"W - MOHEGAN LAKE quad [\[Quad Info\]](#)

1:25,000 1:50,000 1:100,000 1:200,000 Small Medium Large



Coordinates (NAD27):  UTM  DD.DDDD  D/M/S  Show target symbol

[Email this map](#) [Bookmark this map](#) [Print this map](#)