

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION

(1) County Putnam



(3) DEC Well Number

P1642


(2) Township Southeast

WELL COMPLETION REPORT

(4) OWNER Mid Hudson Realty		LOG *	
(5) ADDRESS 1699 Route 6, Suite 1, Carmel, NY 10512		Ground Surface EL. _____ ft. above sea level	
(8) LOCATION OF WELL (See Instructions On Reverse) Show Lat/Long if available and method used: <u>168 John Simpson Rd, Town of Southeast, NY</u> <input type="checkbox"/> GPS <input type="checkbox"/> DEC Website <input type="checkbox"/> Map Interpolation		Top Of Casing is located <u>+1</u> ft. above (+) or below (-) ground surface	
(7) DEPTH OF WELL BELOW LAND SURFACE (Feet) <u>305'</u> <u>10 gpm</u>	(8) DEPTH TO GROUNDWATER BELOW LAND SURFACE (Feet) <u>N/A</u>	DATE MEASURED	
(9) DIAMETER <u>6"</u> in.         in.		TOP OF WELL	
(10) LENGTH <u>122'</u> ft.         in.		0'	
(11) GROUT TYPE / SEALING <u>portland cement</u>		(12) GROUT / SEALING INTERVAL (Feet) FROM <u>90'</u> TO <u>122'</u>	
(13) MAKE & MATERIAL		(14) OPENINGS	
(15) DIAMETER in.         in.		90'	
(16) LENGTH ft.         in.		Drilling in overburden clay and	
(17) DEPTH TO TOP OF SCREEN, FROM TOP OF CASING (Feet)		Drilling in rock for casing	
(18) DATE <u>5/8/01</u>		(19) DURATION OF TEST <u>6 hours</u>	
(20) LIFT METHOD <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift <input type="checkbox"/> Bail		(21) STABILIZED DISCHARGE (GPM) <u>5 gpm</u>	
(22) STATIC LEVEL PRIOR TO TEST (feet/inches below top of casing) <u>20'</u>		(23) MAXIMUM DRAWDOWN (Stabilized) (feet/inches below top of casing) <u>240'</u>	
(24) RECOVERY (Time in hours/minutes) <u>1 hour</u>		(25) Was the water produced during test discharged away from immediate area? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
(26) PUMP INSTALLED? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		(27) DATE <u>5/8/01</u>	
(29) TYPE <u>submersible</u>		(30) MAKE <u>Goulds</u>	
(32) MAXIMUM CAPACITY (GPM) <u>5 gpm</u>		(31) MODEL <u>5GS05412</u>	
(34) METHOD OF DRILLING <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Cable Tool <input type="checkbox"/> Other _____		(33) PUMP INSTALLATION LEVEL FROM TOP OF CASING (Feet) <u>260'</u>	
(36) DATE DRILLING WORK STARTED <u>5/4/01</u>		(35) USE OF WATER (see instructions for choices) <u>residential</u>	
(38) DATE REPORT FILED		(37) DATE DRILLING WORK COMPLETED <u>5/4/01</u>	
(39) DRILLER & COMPANY <u>Perry L. Beal P. F. Beal &amp; Sons, Inc.</u>		(40) DEC REGISTRATION NO. <u>NYRD10105</u>	
* Show log of geologic materials encountered with depth below ground surface, water bearing beds and water levels in each; casings; screens; pump; additional pumping tests and other matters of interest, e.g., water quality (sulphur, salt, methane). Describe repair work. Attach separate sheet if necessary.		305'	
See further instructions titled "Instructions for New York State Well Completion Report".		BOTTOM OF HOLE	
		Set 122' of 6" casing	
		Drilling in rock granite	

NYSDEC COPY

PLAN SKETCH - Indicate north



P1642

Target is 41° 25' 35"N, 73° 38' 53"W - LAKE CARMEL quad [\[Quad](#)

[Info\]](#)

1:25,000 1:50,000 1:100,000 1:200,000



Small

Medium

Large

topozone.com

Copyright © 2000 Maps a la carte, Inc.



Coordinates (NAD27):  UTM  DD.DDDD  D/M/S  Show target symbol