C34

WELL COMPLETION REPORT
3/71

OSCAWANA

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1000

OWNER	NAME: John Viviano	ADDRESS: 20 Overhill Pl., Yonkers, NY 10704
LOCATION OF WELL	(No. & Street): Bullet Hole Rd.,	(Town): Mahopac, N.Y. (Lot Number):

PROPOSED USE OF WELL: [X] DOMESTIC [ ] BUSINESS ESTABLISHMENT [ ] FARM [ ] TEST WELL 690 S [ ] PUBLIC SUPPLY [ ] INDUSTRIAL [ ] AIR CONDITIONING [ ] OTHER (Specify)

DRILLING EQUIPMENT: [X] ROTARY [ ] COMPRESSED AIR PERCUSSION [ ] CABLE PERCUSSION [ ] OTHER (Specify)

CASING DETAILS	LENGTH (feet)	DIAMETER (inches)	WEIGHT PER FOOT		DRIVE SHOE	WAS CASING GROUTED?
	42	6	19 lbs.	[X] THREADED [ ] WELDED	[X] YES [ ] NO	[X] YES [ ] NO

YIELD TEST				HOURS	G.P.M.	YIELD (G.P.M.)
	[ ] BAILED	[X] PUMPED	[ ] COMPRESSED AIR	6	7	7

WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet)	DURING YIELD TEST (feet)	Depth of Completed Well in feet below land surface: 140'
	overflow		

SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) FROM (feet)	TO (feet)

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION
0	32	Drilling in overburden clay & boulders
	32	Hit rock at 32 feet
32	42	Drilling in rock-set casing grouted.
42	140	Drilling in rock-schist

Sketch exact location of well with distances, to at least two permanent landmarks.

RECEIVED
NOV 18 1981
PUTNAM COUNTY
DEPT. OF HEALTH

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
6/29/78	8/30/78	[signature]