

C35

41 24 12 ~~73 41~~  
LAKE CARMEL 73 41 41

WELL COMPLETION REPORT  
3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH  
Division of Environmental Health Services  
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.


REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1001

OWNER	NAME	ADDRESS	
LOCATION OF WELL	(No. & Street)	(Town)	(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING
			<input type="checkbox"/> TEST WELL
			<input type="checkbox"/> OTHER (Specify)
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input checked="" type="checkbox"/> CABLE PERCUSSION
			<input type="checkbox"/> OTHER (Specify)
CASING DETAILS	LENGTH (feet) 71	DIAMETER (inches) 6	WEIGHT PER FOOT 19
			<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED
			DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
			WAS CASING GRO-TED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input checked="" type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input type="checkbox"/> COMPRESSED AIR
		HOURS 6	G.P.M. 15
			YIELD (G.P.M.) 15
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 7 FEET	DURING YIELD TEST (feet) 40 FEET	Depth of Completed Well in feet below Land surface: 95'
SCREEN DETAILS	MAKE	LENGTH OPEN TO AQUIFER (feet)	
	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):
	GRAVEL SIZE (inches)	FROM (feet)	TO (feet)

700 S

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION
FEET	TO FEET	
0	1	TOP SOIL
1	7	LOAM
7	59	SAND + GRAVEL
59	78	BROWN MICR SCHIST
78	89	BLACK MICR
89	95	BROWN MICR SCHIST



DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
MARCH 20	MARCH 22	Denny J. Makarovich

B  
V  
I  
E  
T  
H  
O  
L  
I  
C  
R  
O.