3/71 C5

MOHEGAN

Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1008

OWNER	NAME ALBRECHT, George		ADDRESS RFD #3, Allan Drive, Mahopac, New York	
LOCATION OF WELL	SAME.. (No. & Street)		(Town)	(Lot Number)
PROPOSED USE OF WELL	[X] DOMESTIC	[ ] BUSINESS ESTABLISHMENT	[ ] FARM	[ ] TEST WELL 635' S
	[ ] PUBLIC SUPPLY	[ ] INDUSTRIAL	[ ] AIR CONDITIONING	[ ] OTHER (Specify)
DRILLING EQUIPMENT	[ ] ROTARY	[X] COMPRESSED AIR PERCUSSION	[ ] CABLE PERCUSSION	[ ] OTHER (Specify)

CASING DETAILS	LENGTH (feet)	DIAMETER (inches)	WEIGHT PER FOOT	[X] THREADED [ ] WELDED	DRIVE SHOE [X] YES [ ] NO	WAS CASING GROUTED? [X] YES [ ] NO
	40	6	19			

YIELD TEST	[ ] BAILED	[ ] PUMPED	[X] COMPRESSED AIR	HOURS 4	G.P.M. 10	YIELD (G.P.M.) 10

WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet)	DURING YIELD TEST (feet)	Depth of Completed Well In feet below Land surface:
	20	385	385

SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE FEET	to FEET	FORMATION DESCRIPTION
0	5	Soft sandy silt & clay
5	29	Medium-hard fractured granite
29	385	Medium-hard grey & black granite

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE
200	3
300	4-½
385	10

RECEIVED
JUN 23 1982
PUTNAM COUNTY
DEPT. OF HEALTH

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
5/4/82	5/6/82	Robert A. Mill

MILL DRILLING, INC.
Mohegan