ELL COMPLETION REPORT

71 C56 41 25 02 73 44 07

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1010
LAKE CARMEL

OWNER	NAME L.C.J. Realty (No. & Street)	ADDRESS Carmine Dr. (Town)	17 (Lot Number)	
LOCATION OF WELL	Mahopac N.Y.			
PROPOSED USE OF WELL	[X] DOMESTIC	[ ] BUSINESS ESTABLISHMENT	[ ] FARM	[ ] TEST WELL
	[ ] PUBLIC SUPPLY	[ ] INDUSTRIAL	[ ] AIR CONDITIONING	[ ] OTHER (Specify) 755, H
DRILLING EQUIPMENT	[ ] ROTARY	[X] COMPRESSED AIR PERCUSSION	[ ] CABLE PERCUSSION	[ ] OTHER (Specify)

CASING DETAILS	LENGTH (feet)	DIAMETER (inches)	WEIGHT PER FOOT			DRIVE SHOE	WAS CASING GROUTED
	50	6	19	[X] THREADED	[ ] WELDED	[X] YES [ ] NO	[X] YES [ ] NO

YIELD TEST				HOURS	G.P.M.	YIELD (G.P.M.)
	[ ] BAILED	[ ] PUMPED	[X] COMPRESSED AIR	8		8

WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet)	DURING YIELD TEST (feet)	Depth of Completed Well in feet below Land surface:
	30	125	125

SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)
	—				—
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) FROM (feet) TO (feet)
	—	—			—

TH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION
0	40	Soil
40	125	Bed Rock

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

E WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
Sept 28	Sept 28	[signature]