WELL COMPLETION REPORT
2/71

C59

41 25 27 73 43 42
LAKE CARMEL

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1011

OWNER	NAME: L. SALONPURO		ADDRESS: CAROLYN ROAD, MAHOPAC, NEW YORK (No. & Street) (Town) (Lot Number)	
LOCATION OF WELL	CAROLYN ROAD, MAHOPAC, NEW YORK			
PROPOSED USE OF WELL	[X] DOMESTIC	[ ] BUSINESS ESTABLISHMENT	[ ] FARM	[ ] TEST WELL
	[ ] PUBLIC SUPPLY	[ ] INDUSTRIAL	[ ] AIR CONDITIONING	[ ] OTHER (Specify)
DRILLING EQUIPMENT	[X] ROTARY	[ ] COMPRESSED AIR PERCUSSION	[ ] CABLE PERCUSSION	[ ] OTHER (Specify)

820 S

CASING DETAILS	LENGTH (feet)	DIAMETER (inches)	WEIGHT PER FOOT	[X] THREADED [ ] WELDED	DRIVE SHOE [X] YES [ ] NO	WAS CASING GROUTED? [X] YES [ ] NO
	20	six	19			

YIELD TEST	[ ] BAILED	[ ] PUMPED	[X] COMPRESSED AIR	HOURS	G.P.M.	YIELD (G.P.M.)
				five	2½	2½ GPM

WATER LEVEL	MEASURE FROM LAND SURFACE – STATIC (Specify feet)	DURING YIELD TEST (feet)	Depth of Completed Well in feet below land surface:
	OVERFLOWING		400 ft.

SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet) / TO (feet)

DEPTH FROM LAND SURFACE FEET	to FEET	FORMATION DESCRIPTION
0		SOLID ROCK AT SURFACE
0	20	DRILLING IN SOLID ROCK - SETTING CASING-GROUTED
20	400	DRILLING IN ROCK - GRANITE

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
5/8/73	8/10/73	P. F. BEAL & SONS, INC.