

LAKE CARMEL


This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1013

OWNER	NAME DAVID P. GILMORE <small>(No. &amp; Street)</small>		ADDRESS Longdale Rd. Mahopac N.Y. <small>(Town)</small>		SUBDIV. <small>(Lot Number)</small> LOT # 4	
LOCATION OF WELL	#4 Casse Court		Mahopac - Town of Carmel		TOWN OF CARMEL TAX MAP # 168 BLOCK # 02 TAX LOT # 06	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL		
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)		
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)	635 5	
CASING DETAILS	LENGTH (feet) 20'	DIAMETER (inches) 6"	WEIGHT PER FOOT 14 lb	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	WAS CASING GROUTED? <input type="checkbox"/> YES <input type="checkbox"/> NO
	YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 3	G.P.M. 35
WATER LEVEL	MEASURE FROM LAND SURFACE -- STATIC (Specify feet) 4'		DURING YIELD TEST (feet) 85'		Depth of Completed Well in feet below Land surface: 85'	
	SCREEN DETAILS					LENGTH OPEN TO AQUIFER (feet)

DEPTH FROM LAND SURFACE FEET TO FEET		FORMATION DESCRIPTION
		Hardpan 0 to 15
		5 ft in rock
		20 feet casing
0	15	HAROPANI
15	85	BEDROCK
If yield was tested at different depths during drilling, list below		
FEET	GALLONS PER MINUTE	



DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature) P. Stuart Savoy
---------------------	----------------	---