WELL COMPLETION REPORT
3/71

K51 LAKE CARMEL

PUTNAM COUNTY DEPARTMENT OF HEALT
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YOR

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

41 26 54 73 40 37

P1033

OWNER	NAME: Siegfried Cont. (No. & Street)	ADDRESS: 58 Glenelda Ridge (Town) Carmel N.Y. (Lot Number)
LOCATION OF WELL	Nichols ST Lake Carmel N.Y.	
PROPOSED USE OF WELL	[X] DOMESTIC; [ ] BUSINESS ESTABLISHMENT; [ ] FARM; [ ] TEST WELL; [ ] PUBLIC SUPPLY; [ ] INDUSTRIAL; [ ] AIR CONDITIONING; [ ] OTHER (Specify)	660 5
DRILLING EQUIPMENT	[ ] ROTARY; [X] COMPRESSED AIR PERCUSSION; [ ] CABLE PERCUSSION; [ ] OTHER (Specify)	
CASING DETAILS	LENGTH (feet): 30; DIAMETER (inches): 6; WEIGHT PER FOOT: 19; [X] THREADED; [X] WELDED; DRIVE SHOE [X] YES [ ] NO; WAS CASING GROUTED? [X] YES [ ] NO	
YIELD TEST	[ ] BAILED; [ ] PUMPED; [X] COMPRESSED AIR; HOURS: 8; G.P.M.: 7; YIELD (G.P.M.): 7	
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet): 15; DURING YIELD TEST (feet): 273; Depth of Completed Well in feet below Land surface: 275	
SCREEN DETAILS	MAKE; LENGTH OPEN TO AQUIFER (feet); SLOT SIZE; DIAMETER (inches); IF GRAVEL PACKED: Diameter of well including gravel pack (inches): ; GRAVEL SIZE (inches); FROM (feet); TO (feet)	

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION
0	1	Soil
1	275	Bedrock.

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

RECEIVED
MAY 17 1982
PUTNAM COUNTY
DEPT. OF HEALTH

DATE WELL COMPLETED | DATE OF REPORT | WELL DRILLER (Signature)