

WELL COMPLETION REPORT  
3/71

K10

LAKE CARMEL  
41 26 59 73 39 49

PUTNAM COUNTY DEPARTMENT OF HEALTH  
Division of Environmental Health Services  
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1036

OWNER	NAME Vincent Condura		ADDRESS			
LOCATION OF WELL	(No. & Street) Carly Rd. Lake Carmel		(Town)		(Lot Number)	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL	640 S	
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)		
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)		
CASING DETAILS	LENGTH (feet) 153	DIAMETER (Inches) 7	WEIGHT PER FOOT 26	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 3	G.P.M. 25	YIELD (G.P.M.) 25
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 30		DURING YIELD TEST (feet) total drawdown		Depth of Completed Well in feet below Land surface: 320	
SCREEN DETAILS	MAKE					LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (Inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (Inches):	GRAVEL SIZE (Inches) FROM (feet)	TO (feet)

DEPTH FROM LAND SURFACE FEET TO FEET		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
0	6	clay	
6	15	sand	
15	110	clay	
110	115	gravel	
115	143	clay	
143	320	ledge	
If yield was tested at different depths during drilling, list below			
FEET	GALLONS PER MINUTE		

DATE WELL COMPLETED 2/16/73	DATE OF REPORT 2/18/73	WELL DRILLER (Signature) <i>Robert M. Buzel</i>
--------------------------------	---------------------------	--