

WELL COMPLETION REPORT
3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1040

41 27 21 73 48 09

OWNER	NAME Arthur Meyers		ADDRESS P.O. Box 613, Carmel, NY 10512			
LOCATION OF WELL	(No. & Street) North Richardsville Rd.		(Town) Carmel, NY		(Lot Number)	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL	840, S	
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)		
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)		
CASING DETAILS	LENGTH (feet) 30'	DIAMETER (inches) 6"	WEIGHT PER FOOT 19 lbs.	<input checked="" type="checkbox"/> THREADED	<input type="checkbox"/> WELDED	
				DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
YIELD TEST	<input type="checkbox"/> BAILED	<input checked="" type="checkbox"/> PUMPED	<input type="checkbox"/> COMPRESSED AIR	HOURS 6	G.P.M. 5	
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 37'		DURING YIELD TEST (feet)		YIELD (G.P.M.) 5	
					Depth of Completed Well in feet below Land surface: 325'	
SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) FROM (feet) TO (feet)	

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
0	5	Drilling in overburden clay & boulders	
		Hit rock at 5 feet	
5	21	Drilling in rock set casing grouted.	
21	325	Drilling in rock granite.	


If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

RECEIVED

FEB 3 1982

PUTNAM COUNTY
DEPT. OF HEALTH

DATE WELL COMPLETED 5/27/81	DATE OF REPORT 1/7/82	WELL DRILLER (Signature) 
--------------------------------	--------------------------	--