K27

LAKE CARMEL

41 28 32 73 39 48

WELL COMPLETION REPORT
3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1049

OWNER	NAME: McGlasson Builders, Inc.	ADDRESS: 21 AveryvRoad, Carmel, N.Y.
LOCATION OF WELL	(No. & Street): Corner of Livingston Rd. & Hamilton Drive, (Town): Lake Carmel, (Lot Number): N.Y.	
PROPOSED USE OF WELL	[XX] DOMESTIC; [ ] BUSINESS ESTABLISHMENT; [ ] FARM; [ ] TEST WELL; [ ] PUBLIC SUPPLY; [ ] INDUSTRIAL; [ ] AIR CONDITIONING; [ ] OTHER (Specify)	640 S
DRILLING EQUIPMENT	[ ] ROTARY; [ ] COMPRESSED AIR PERCUSSION; [XX] CABLE PERCUSSION; [ ] OTHER (Specify)	
CASING DETAILS	LENGTH (feet): 21'; DIAMETER (inches): 8"; WEIGHT PER FOOT: ; [XX] THREADED [ ] WELDED; DRIVE SHOE [ ] YES [XX] NO; WAS CASING GROUTED? [XX] YES [ ] NO	
YIELD TEST	[ ] BAILED; [XX] PUMPED; [ ] COMPRESSED AIR; HOURS: 2 Hrs.; G.P.M.: 9; YIELD (G.P.M.): 9	
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet): 18'; DURING YIELD TEST (feet): 18'; Depth of Completed Well in feet below Land surface: 102'.	
SCREEN DETAILS	MAKE: ; LENGTH OPEN TO AQUIFER (feet): ; SLOT SIZE: ; DIAMETER (inches): ; IF GRAVEL PACKED: ; Diameter of well including gravel pack (inches): ; GRAVEL SIZE (inches): ; FROM (feet): ; TO (feet):	

DEPTH FROM LAND SURFACE FEET	to FEET	FORMATION DESCRIPTION
0	20	Rock and Shale
20	102	Loam, sandy, clay

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE
65'	4
85'	6
102'	9

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
3/17/72	4/10/72	Stephen Awrytis Red & Rd