h3

WELL COMPLETION REPORT LAKE CARMEL
3/71

41 29 46 73 35 43

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION P1051

OWNER	NAME: FRANK YODICE	ADDRESS: COR. ARDSLEIGH + NOONAN RD., LAKE CARMEL (No. & Street) (Town) (Lot Number)
LOCATION OF WELL	CORNER OF ARDSLEIGH AND NOONAN RD., LAKE CARMEL	
PROPOSED USE OF WELL	[X] DOMESTIC; [ ] BUSINESS ESTABLISHMENT; [ ] FARM; [ ] TEST WELL; [ ] PUBLIC SUPPLY; [ ] INDUSTRIAL; [ ] AIR CONDITIONING; [ ] OTHER (Specify) 700 S	
DRILLING EQUIPMENT	[X] ROTARY; [ ] COMPRESSED AIR PERCUSSION; [ ] CABLE PERCUSSION; [ ] OTHER (Specify)	

CASING DETAILS	LENGTH (feet)	DIAMETER (inches)	WEIGHT PER FOOT	[X] THREADED [ ] WELDED	DRIVE SHOE [X] YES [ ] NO	WAS CASING GROUTED? [X] YES [ ] NO
	80	SIX	19 lb.			

YIELD TEST	[ ] BAILED	[ ] PUMPED	[X] COMPRESSED AIR	HOURS	G.P.M.	YIELD (G.P.M.)
				FIVE	15	FIFTEEN

WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet)	DURING YIELD TEST (feet)	Depth of Completed Well in feet below Land surface:
	22'		175'

SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) / FROM (feet) / TO (feet)

DEPTH FROM LAND SURFACE FEET	to FEET	FORMATION DESCRIPTION
0	70	Drilling in overburden (clay + boulders)
		Hit solid rock at 70 ft.
70	80	Drilling in rock - setting casing - grouted
80	175	Drilling in rock - granite

Sketch exact location of well with distances, to at least two permanent landmarks.

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
9/23/72	4/11/73	P. F. BEAL + SONS, INC. Malcolm T. Beal Pres