K43 LAKE CARMEL

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1062

41 27 05 73 40 09

OWNER	NAME: Joe Cmar	ADDRESS: Horsepond Rd Carmel N.Y.
LOCATION OF WELL	(No. & Street): Lincoln Dr	(Town): Lake Carmel N.Y. (Lot Number):
PROPOSED USE OF WELL	[X] DOMESTIC [ ] BUSINESS ESTABLISHMENT [ ] FARM [ ] TEST WELL [ ] PUBLIC SUPPLY [ ] INDUSTRIAL [ ] AIR CONDITIONING [ ] OTHER (Specify)	670 5
DRILLING EQUIPMENT	[ ] ROTARY [X] COMPRESSED AIR PERCUSSION [ ] CABLE PERCUSSION [ ] OTHER (Specify)	
CASING DETAILS	LENGTH (feet): 30 DIAMETER (inches): 6 WEIGHT PER FOOT: 19 [X] THREADED [ ] WELDED DRIVE SHOE: [X] YES [ ] NO WALL CASING (GROUTED): [X] YES [ ] NO	
YIELD TEST	[ ] BAILED [ ] PUMPED [X] COMPRESSED AIR HOURS: 2 DEPTH: 20 YIELD (G.P.M.): 20	
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet): 18 DURING YIELD TEST (feet): totaldrawdown	Depth of Completed Well in feet below land surface: 280
SCREEN DETAILS	MAKE:	LENGTH OPEN TO AQUIFER (feet):
	SLOT SIZE: DIAMETER (inches): IF GRAVEL PACKED: Diameter of well including gravel pack (inches): GRAVEL SIZE (inches): FROM (feet): TO (feet):	

DEPTH FROM LAND SURFACE FEET	to FEET	FORMATION DESCRIPTION
0	15	overburden
15	25	sandstone
25	280	granite

Sketch exact location of well with distances, to at least two permanent landmarks.

If yield was tested at different depths during drilling, list below:

FEET	GALLONS PER MINUTE
200	1

WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
7/1/75	8/1/75	Henry M Ball

Boyd Artesian Well Co., Inc.
R. D. 5 - Route 52
Carmel, N. Y. 10512