WELL COMPLETION REPORT
3/71 K4t

LAKE CARMEL

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1065

41 28 54 73 39 42

OWNER	NAME: AURA GALLI (No. & Street)	ADDRESS: R.D.7 FILERS ACRES (Town)	CARMEL, N.Y. (Lot Number)	
LOCATION OF WELL	MARIE ROAD	KENT	13	
PROPOSED USE OF WELL	☑ DOMESTIC ☐ BUSINESS ESTABLISHMENT ☐ FARM ☐ TEST WELL ☐ PUBLIC SUPPLY ☐ INDUSTRIAL ☐ AIR CONDITIONING ☐ OTHER (Specify)	995 H		
DRILLING EQUIPMENT	☑ ROTARY ☑ COMPRESSED AIR PERCUSSION ☐ CABLE PERCUSSION ☐ OTHER (Specify)			
CASING DETAILS	LENGTH (feet): 40 ft; DIAMETER (inches): 6"; WEIGHT PER FOOT: 19 lb; ☑ THREADED ☐ WELDED; DRIVE SHOE: ☑ YES ☐ NO; WAS CASING GROUTED? ☐ YES ☑ NO			
YIELD TEST	☐ BAILED ☐ PUMPED ☑ COMPRESSED AIR; HOURS: 3 hrs; G.P.M.: 12 gals; YIELD (G.P.M.): 12 gals			
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet): 3 ft; DURING YIELD TEST (feet): 265 ft; Depth of Completed Well in feet below Land surface: 265 ft			
SCREEN DETAILS	MAKE: ; LENGTH OPEN TO AQUIFER (feet): ; SLOT SIZE: ; DIAMETER (inches): ; IF GRAVEL PACKED: ; Diameter of well including gravel pack (inches): ; GRAVEL SIZE (inches): ; FROM (feet): ; TO (feet):			

DEPTH FROM LAND SURFACE FEET to FEET	FORMATION DESCRIPTION
265 ft	Blue Clay 35 ft
	set Casing 40"
	With Drive shoe

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different dept'ts during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
9/30/73	11/22/73	Edw Savage