

WELL COMPLETION REPORT
3/71

41 29 22 73 41 55
~~412230 734755~~

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1067

OWNER	NAME Fernando Barbalaco		ADDRESS 1 Michaels Court Carmel, NY	
LOCATION OF WELL	(No. & Street) 1 Michaels Court		(Town) Kent	(Lot Number) 1
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)
CASING DETAILS	LENGTH (feet) 21	DIAMETER (Inches) 6	WEIGHT PER FOOT 19	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED
				DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 2 G.P.M. 5 YIELD (G.P.M.) 5
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 40		DURING YIELD TEST (feet) total drawdown	Depth of Completed Well in feet below Land surface: 395
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (Inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (Inches):

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
FEET	to FEET		
0	2	organic soils	
2	395	granite	

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED 5/29/84	DATE OF REPORT 11/6/84	WELL DRILLER (Signature) <i>[Signature]</i>
--------------------------------	---------------------------	--