

WELL COMPLETION REPORT
3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

KEO **LAKE CARMEL**
41 29 25 73 44 44

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1079

OWNER	NAME Dutcher Homes		ADDRESS Box 73 Patterson	
LOCATION OF WELL	(No. & Street) Rambler Road		(Town) Kent	(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify) 750 S
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)
CASING DETAILS	LENGTH (feet) 38	DIAMETER (inches) 6	WEIGHT PER FOOT 19	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED
	MEASURE FROM LAND SURFACE - STATIC (Specify feet)		DURING YIELD TEST (feet)	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
WATER LEVEL	Total Drawdown		Depth of Completed Well in feet below Land surface:	202
SCREEN DETAILS	MAKE	LENGTH OPEN TO AQUIFER (feet)		
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches);
				GRAVEL SIZE (inches) FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
FEET	to FEET		
0	22	Overburden	
22	202	Ledge	

If yield was tested at different depths during drilling, list below:

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED 9/21/83	DATE OF REPORT 9/30/83	WELL DRILLER (Signature) <i>Wesley M. Boyd</i>
--------------------------------	---------------------------	---