

41 27 49 73 40 11

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1083

OWNER	NAME <u>Miguel Schupp</u>		ADDRESS	
LOCATION OF WELL	(No. & Street)		(Town)	(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC		<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM
	<input type="checkbox"/> PUBLIC SUPPLY		<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY		<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION
CASING DETAILS	LENGTH (feet) <u>110'</u>	DIAMETER (inches) <u>7"</u>	WEIGHT PER FOOT <u>23</u>	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS <u>2</u>
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) <u>15'</u>		DURING YIELD TEST (feet) <u>15'</u>	
SCREEN DETAILS	SLOT SIZE		DIAMETER (inches)	IF GRAVEL PACKED:
	Diameter of well including gravel pack (inches):		GRAVEL SIZE (inches)	FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
FEET	to FEET		
0	60'	cover boulder	
60'	150	soft rock - sandstone	
100'	170	Hard Rock	
170	180	- sand stone high water yield - well filled in 5' at time of completion	

If yield was tested at different depths during drilling, list below			
FEET	GALLONS PER MINUTE		
DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)	
	<u>7/7/72</u>	<u>Miguel M. Boyel</u>	

BOYD ARTESIAN WELL CO.  
RFD 3  
ROUTE 52  
CARMEL, N.Y.