

WELL COMPLETION REPORT  
3/71

PA 16

BREWSTER

PUTNAM COUNTY DEPARTMENT OF HEALTH  
Division of Environmental Health Services  
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.


REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1099

41 29 41 73 32 14

OWNER	NAME Thomas + Francine Capaldo		ADDRESS PO Box 340	
LOCATION OF WELL	(No. & Street) Haviland + Brimstone RD		(Town) Patterson NY	(Lot Number) 19
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify) S35 C
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input checked="" type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)
CASING DETAILS	LENGTH (feet) 30	DIAMETER (Inches) 6	WEIGHT PER FOOT 17	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
			<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input checked="" type="checkbox"/> SAILED	<input type="checkbox"/> PUMPED	<input type="checkbox"/> COMPRESSED AIR	HOURS 6
				G.P.M. 7 1/2
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 14'		DURING YIELD TEST (feet) 100'	
			Depth of Completed Well in feet below Land surface: 182	
SCREEN DETAILS	MAKE Linn	LENGTH OPEN TO AQUIFER (feet)		
	SLOT SIZE	DIAMETER (Inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (Inches):
				GRAVEL SIZE (Inches) FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION
FEET	TO FEET	
0	1	TOP SOIL
1	7	LOAM
7	18	CLAY
18		182 BLACK GRANITE



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE
/	/

DATE WELL COMPLETED 10/5/84	DATE OF REPORT	WELL DRILLER (Signature) Ernie J. Malambuk
--------------------------------	----------------	---