

PASO BREWSTER

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.


REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1102

41 28 52 73 32 20

OWNER	NAME: LAFLOZ JULIA NAGY		ADDRESS: 53 DIVISION ST DANBURY	
LOCATION OF WELL	(No. & Street): HOMER & ALLEN		(Town): PUT LR. PATTERSON, N.Y.	(Lot Number):
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify): SSO S
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify):
CASING DETAILS	LENGTH (feet): 20' 1"	DIAMETER (inches): 6 5/8 X .252	WEIGHT PER FOOT: 17	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED
				DRIVE SHOE: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
				WAS CASING GROUTED?: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input checked="" type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS: 3
				G.P.M.: 12
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet): 15		DURING YIELD TEST (feet):	
				Depth of Completed Well in feet below Land surface: 105
SCREEN DETAILS	MAKE:	LENGTH OPEN TO AQUIFER (feet):		
	SLOT SIZE:	DIAMETER (inches):	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):
				GRAVEL SIZE (inches) FROM (feet) TO (feet):

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION
FEET	TO FEET	
0	8	OVER BURDEN
8	105	GRANITE GNEISS <sup>Big granite</sup>
24'		Small Aquifer
35-37		fault major aquifer
		Bit size 5 5/16"
If yield was tested at different depths during drilling, list below		
FEET	GALLONS PER MINUTE	
25	Est 2 GPM	
45	12	
105	15 → 12	
40	12-15	
30	7	
23	2	



RECEIVED  
FEB 3 1984  
PUTNAM COUNTY  
DEPT. OF HEALTH

DATE WELL COMPLETED: 9/1/83	DATE OF REPORT: 9/2/83	WELL DRILLER (Signature): [Signature]
-----------------------------	------------------------	---------------------------------------