PA38 BREWSTER

WELL COMPLETION REPORT
3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1110

41 28 28 73 32 58

OWNER	NAME: McGlasson Builders (No. & Street)	ADDRESS: Main Street, Carmel, NY (Town)		
LOCATION OF WELL	Quogue Road, Putnam Lake			(Lot Number) 1
PROPOSED USE OF WELL	[X] DOMESTIC	[ ] BUSINESS ESTABLISHMENT	[ ] FARM	[ ] TEST WELL
	[ ] PUBLIC SUPPLY	[ ] INDUSTRIAL	[ ] AIR CONDITIONING	[ ] OTHER (Specify) 670 H
DRILLING EQUIPMENT	[ ] ROTARY	[X] COMPRESSED AIR PERCUSSION	[ ] CABLE PERCUSSION	[ ] OTHER (Specify)
CASING DETAILS	LENGTH (feet): 21	DIAMETER (inches): 6	WEIGHT PER FOOT: 19	[X] THREADED [ ] WELDED
	DRIVE SHOE: [X] YES [ ] NO	WAS CASING GROUTED? [X] YES [ ] NO		
YIELD TEST	[ ] BAILED	[ ] PUMPED	[X] COMPRESSED AIR	HOURS: 8
	G.P.M.:	YIELD (G.P.M.): 30		
WATER LEVEL	MEASURE FROM LAND SURFACE – STATIC (Specify feet):	DURING YIELD TEST (feet): Total Drawdown	Depth of Completed Well in feet below Land surface: 255	
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):
	GRAVEL SIZE (inches)	FROM (feet)	TO (feet)	

DEPTH FROM LAND SURFACE FEET	to FEET	FORMATION DESCRIPTION
0	8	overburden
8	255	ledge

Sketch exact location of well with distances, to at least two permanent landmarks.

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE
200	30

RECEIVED
APR 13 1983
PUTNAM COUNTY
DEPT. OF HEALTH

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
Jan. 4 '83	1.5.83	

rec'd. 1/12/83