PAZ BREWSTER

COUNTY OFFICE BUILDING - CARMEL, NEW YOR

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

41 29 33 73 36 19

P1117

OWNER	NAME: Bernard Kessman	ADDRESS: Cornwall Hill Road, Patterson, NY
LOCATION OF WELL	(No. & Street): same.	(Town) / (Lot Number)

PROPOSED USE OF WELL: [X] DOMESTIC [ ] BUSINESS ESTABLISHMENT [ ] FARM [ ] TEST WELL [ ] PUBLIC SUPPLY [ ] INDUSTRIAL [ ] AIR CONDITIONING [ ] OTHER (Specify) 470 S

DRILLING EQUIPMENT: [ ] ROTARY [X] COMPRESSED AIR PERCUSSION [ ] CABLE PERCUSSION [ ] OTHER (Specify).

CASING DETAILS	LENGTH (feet)	DIAMETER (inches)	WEIGHT PER FOOT			DRIVE SHOE	WAS CASING GROUTED?
	51	6	19	[X] THREADED	[ ] WELDED	[X] YES [ ] NO	[X] YES [ ] NO

YIELD TEST				HOURS	G.P.M.	YIELD (G.P.M.)
	[ ] BAILED	[ ] PUMPED	[X] COMPRESSED AIR	4	15	15

WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet)	DURING YIELD TEST (feet)	Depth of Completed Well in feet below land surface:
	60	185	185

SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)		
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet)	TO (feet)

DEPTH FROM LAND SURFACE FEET	TO FEET	FORMATION DESCRIPTION
0	34	Sandy silt & gravel
34	40	Grey hardpan
40	185	Medium to hard white limestone.

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

Sketch exact location of well with distances, to at least two permanent landmarks.



DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
6/21/84	6/22/84	Robert H. Mill, Pres.-MILL DRILLING, INC.