5/11 BREWSTER

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1124

41 24 54 73 36 45

OWNER	NAME: JOHN FORBES	ADDRESS: Pumphouse Road, Brewster, NY 10509
LOCATION OF WELL	(No. & Street): Pumphouse Road	(Town): Brewster, NY (Lot Number):
PROPOSED USE OF WELL	[X] DOMESTIC; [ ] BUSINESS ESTABLISHMENT; [ ] FARM; [ ] TEST WELL; [ ] PUBLIC SUPPLY; [ ] INDUSTRIAL; [ ] AIR CONDITIONING; [ ] OTHER (Specify)	480 S
DRILLING EQUIPMENT	[X] ROTARY to 190'; [X] COMPRESSED AIR PERCUSSION 190' to 325'; [ ] CABLE PERCUSSION; [ ] OTHER (Specify)	
CASING DETAILS	LENGTH (feet): 190; DIAMETER (inches): 6; WEIGHT PER FOOT: 19; [X] THREADED [ ] WELDED; DRIVE SHOE [X] YES [ ] NO; WAS CASING GROUTED? [ ] YES [X] NO	
YIELD TEST	[ ] BAILED [ ] PUMPED [X] COMPRESSED AIR; HOURS: 4; G.P.M.: 20; YIELD (G.P.M.): 20	
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet): 80; DURING YIELD TEST (feet): 325	Depth of Completed Well In feet below land surface: 325
SCREEN DETAILS	MAKE: ; LENGTH OPEN TO AQUIFER (feet): ; SLOT SIZE: ; DIAMETER (inches): ; IF GRAVEL PACKED: Diameter of well including gravel pack (inches): ; GRAVEL SIZE (inches): ; FROM (feet): ; TO (feet):	

DEPTH FROM LAND SURFACE FEET	TO FEET	FORMATION DESCRIPTION
0	168	Hardpan & Boulders
168	180	Soft Weathered Bedrock
180	325	Medium-Hard Grey, Black & Pink Granite

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below.

FEET	GALLONS PER MINUTE
275	2-½
300	4-½
325	20

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
9/21/83	10/4/83	Robert M. Mill, Pres.-MILL DRILLING, INC.