

WELL COMPLETION REPORT

3/71

314

LAKE CARMEL  
41 22 35 73 3754

PUTNAM COUNTY DEPARTMENT OF HEALTH

Division of Environmental Health Services

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1126

OWNER	NAME Peter Beitzel		ADDRESS 7 Merritt St., Port Chester, NY 10573				
LOCATION OF WELL	(No. & Street) Guinea Road		(Town) Brewster, NY		(Lot Number)		
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL	C, 300		
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)			
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)			
	CASING DETAILS	LENGTH (feet) 33'	DIAMETER (inches) 6"	WEIGHT PER FOOT 19 lbs.	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input checked="" type="checkbox"/> PUMPED	<input type="checkbox"/> COMPRESSED AIR	HOURS 6	G.P.M. 20+	YIELD (G.P.M.) 20+	
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 20'		DURING YIELD TEST (feet)		Depth of Completed Well in feet below Land surface: 210'		
SCREEN DETAILS	MAKE					LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet)	TO (feet)

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION
0	15	Drilling in overburden clay and boulders
		Hit rock at 15 feet
15	33	Drilling in rock, set casing, grouted.
33	210	Drilling in granite.

Sketch exact location of well with distances, to at least two permanent landmarks.

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED 12/24/83	DATE OF REPORT 2/14/84	WELL DRILLER (Signature) <i>Michael R. Beitzel</i>
---------------------------------	---------------------------	---