

521

Lake Carmel

WELL COMPLETION REPORT

41 23 15 73 38 45

Report is to be completed by well driller and submitted to Health Department, together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality, before certificate of construction compliance is issued.

Well construction to be in accordance with Bulletin SD-62
"RULES & REGULATIONS RELATING TO INDIVIDUAL WATER SUPPLIES"

370 F

LOCATION: MUNICIPALITY Well # 2 SECTION _____ BLOCK _____ LOT _____

WELL OWNER: A. Nitti, ~~XXXXXXXX~~ Merrick Road, Brewville, Brewster, New York
Name Street Address City and Town

WELL DRILLER: MILL DRILLING, INC., Putnam Avenue, Brewster, New York
Name Street Address City and Town

CASING DETAILS		YIELD TEST		WATER LEVEL		SCREEN DETAILS	
Length:	121 Feet	Bailed		(measure from land surface)			
		or					
		XX Pumped	2	Hours Static:	8	Feet Make:	
				When Bailed			
Diameter:	6 Inches	Yield:	5	G.P.M. or Pumped	340	Feet Length	Ft. Size
Kind:	Steel					Diameter	In.

TOTAL DEPTH OF WELL 340 FEET

WELL LOG

Depth From Ground Surface	Give description of formations penetrated, such as: peat, silt, sand, gravel, clay, hardpan, shale, sandstone, granite, etc. Include size of gravel (diameter and sand (fine, medium, coarse), color of material, structure (Loose, packed, cemented, soft, hard). For example: 0 ft. to 27 ft. fine, packed, yellow sand; 27 ft. to 134 ft. gray granite.
0 Ft. to 117 Ft.	Blue hardpan and boulders.
117 Ft. to 340 Ft.	Hard gray granite.
Ft. to Ft.	

Date Well Was Completed August 18, 1971 Date of Report September 10, 1971

Well Driller Robert M. Mill Pres.
Signature
MILL DRILLING, INC.