

523 LAKE CARMEL  
41 23 25 73 38 28

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.


REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1133

OWNER	NAME Leonard Cerlich		ADDRESS Putnam Avenue, Brewster, New York		
LOCATION OF WELL	(No. & Street) Nelson Boulevard		(Town) Brewster		(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL	
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify) 410 F	
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)	
CASING DETAILS	LENGTH (feet) 80	DIAMETER (inches) 6	WEIGHT PER FOOT 19	<input checked="" type="checkbox"/> THREADED	<input type="checkbox"/> WELDED
				DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 4	G.P.M. 7
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet) 30		DURING YIELD TEST (feet) 320		Depth of Completed Well in feet below Land surface: 320
	MAKE				LENGTH OPEN TO AQUIFER (feet)
SCREEN DETAILS	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION
FEET	TO FEET	
0	75	Hardpan and boulders.
75	320	Medium hard granite.

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED 9-23-77	DATE OF REPORT 10-4-77	WELL DRILLER (Signature) Robert M Mill
--------------------------------	---------------------------	---

NELSON BOULEVARD  
MILL DRILLING, INC.