3/24 BREWSTER

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

41 23 47 43 37 11

P1134

| | | |
|---|---|---|
| OWNER | NAME: A & J Builders, Inc. | ADDRESS: PO Box 8082, New Fairfield, CT 06810 |
| LOCATION OF WELL | (No. & Street): Clearview Estates, North Brewster Road; (Town): Brewster, NY | (Lot Number): 7 |

PROPOSED USE OF WELL: [X] DOMESTIC [ ] BUSINESS ESTABLISHMENT [ ] FARM [ ] TEST WELL [ ] PUBLIC SUPPLY [ ] INDUSTRIAL [ ] AIR CONDITIONING [ ] OTHER (Specify) 400 S

DRILLING EQUIPMENT: [X] ROTARY to 203 [X] COMPRESSED AIR 203 to 500 [ ] CABLE PERCUSSION [ ] OTHER (Specify)

| CASING DETAILS | LENGTH (feet) | DIAMETER (inches) | WEIGHT PER FOOT | | DRIVE SHOE | WAS CASING GROUTED |
|---|---|---|---|---|---|---|
| | 203 | 6 | 17 | [X] THREADED [ ] WELDED | [X] YES [ ] NO | [ ] YES [X] NO |

| YIELD TEST | | | | HOURS | G.P.M. | YIELD (G.P.M.) |
|---|---|---|---|---|---|---|
| | [ ] BAILED | [ ] PUMPED | [X] COMPRESSED AIR | 4 | 6 | 6 |

| WATER LEVEL | MEASURE FROM LAND SURFACE—STATIC (Specify feet) | DURING YIELD TEST (feet) | Depth of Completed Well in feet below land surface: |
|---|---|---|---|
| | 60 | 500 | 500 |

| SCREEN DETAILS | MAKE | | | | LENGTH OPEN TO AQUIFER (feet) | |
|---|---|---|---|---|---|---|
| | SLOT SIZE | DIAMETER (inches) | IF GRAVEL PACKED: | Diameter of well including gravel pack (inches): | GRAVEL SIZE (inches) | FROM (feet) / TO (feet) |

| DEPTH FROM LAND SURFACE FEET to FEET | | FORMATION DESCRIPTION |
|---|---|---|
| 0 | 189 | Hardpan & boulders. |
| 189 | 193 | Brown weathered bedrock |
| 193 | 500 | Hard granite |

Sketch exact location of well with distances, to at least two permanent landmarks.




If yield was tested at different depths during drilling, list below

| FEET | GALLONS PER MINUTE |
|---|---|
| 440 | 2 |
| 480 | 3 |
| 500 | 6 |

NORTH BREWSTER ROAD

| DATE WELL COMPLETED | DATE OF REPORT | WELL DRILLER (Signature) | |
|---|---|---|---|
| 2/19/85 | 2/19/85 | Robert M Mill | MILL DRILLING, INC. Robert M. Mill, Pres. |