WELL COMPLETION REPORT
3/71

S 29 BREWSTER

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

41 26 16 73 33 51

P1139

OWNER	NAME		ADDRESS			
LOCATION OF WELL	(No. & Street) River Run Farm		(Town) Putnam Lake Road, Brewster, NY			(Lot Number)
PROPOSED USE OF WELL	☐ DOMESTIC	☐ BUSINESS ESTABLISHMENT	☒ FARM	☐ TEST WELL		
	☐ PUBLIC SUPPLY	☐ INDUSTRIAL	☐ AIR CONDITIONING	☐ OTHER (Specify)		
DRILLING EQUIPMENT	☒ ROTARY to 70'	☒ COMPRESSED AIR PERCUSSION 70 to 175'	☐ CABLE PERCUSSION	☐ OTHER (Specify)		
CASING DETAILS	LENGTH (feet) 70'	DIAMETER (inches) 5"	WEIGHT PER FOOT 19	☒ THREADED ☐ WELDED	DRIVE SHOE ☒ YES ☐ NO	WAS CASING GROUTED? ☒ YES ☐ NO
YIELD TEST	☐ BAILED	☐ PUMPED	☒ COMPRESSED AIR	HOURS 4	G.P.M. 80	YIELD (G.P.M.) 80
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet) 12		DURING YIELD TEST (feet) 175		Depth of Completed Well in feet below Land surface: 175	
SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) FROM (feet)	TO (feet)

DEPTH FROM LAND SURFACE FEET	to FEET	FORMATION DESCRIPTION
0	80	Sand & Gravel
80	175	Medium-Hard Pink & White

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE
170	80

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
[illegible]	10/20/81	Robert M. Nim