WELL COMPLETION REPORT
3/71

BREWSTER

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1140

41 24 59 73 36 50

OWNER	NAME: Edward Samuels		ADDRESS: Laurel Drive, Ton. Lk., Brewster, NY	
LOCATION OF WELL	(No. & Street): Birch Drive		(Town): Brewster, New York	(Lot Number):
PROPOSED USE OF WELL	[X] DOMESTIC	[•] BUSINESS ESTABLISHMENT	[ ] FARM	[ ] TEST WELL
	[ ] PUBLIC SUPPLY	[ ] INDUSTRIAL	[ ] AIR CONDITIONING	[ ] OTHER (Specify) 450 L
DRILLING EQUIPMENT	[ ] ROTARY	[XX] COMPRESSED AIR PERCUSSION	[ ] CABLE PERCUSSION	[ ] OTHER (Specify)

CASING DETAILS	LENGTH (feet)	DIAMETER (inches)	WEIGHT PER FOOT			DRIVE SHOE		WAS CASING GROUTED?	
	99	6	17	[X] THREADED	[ ] WELDED	[X] YES	[ ] NO	[ ] YES	[X] NO

YIELD TEST				HOURS	G.P.M.	YIELD (G.P.M.)
	[ ] BAILED	[ ] PUMPED	[X] COMPRESSED AIR	4	12	12

WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet)	DURING YIELD TEST (feet)	Depth of Completed Well in feet below Land surface:
	70	185	195

SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet) / TO (feet)

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION
0	88	Blue hardpan.
88	93	Weathered ledge.
93	195	Hard gray granite.

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE
175	12

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
9/9/73	9/19/73	Robert M Mill, President — MILL DRILLING, INC.