

BREWSTER

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1142

41 28 39 23 34 47

OWNER	NAME Virginia Kroha		ADDRESS Drewville Rd., Brewster, NY 10509		
LOCATION OF WELL	(No. & Street) Route 22		(Town) Brewster, NY		(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL	440 L
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)	
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)	
CASING DETAILS	LENGTH (feet) 30'	DIAMETER (inches) 6"	WEIGHT PER FOOT 19 lbs.	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
					WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input checked="" type="checkbox"/> PUMPED	<input type="checkbox"/> COMPRESSED AIR	HOURS 6	G.P.M. 10+
					YIELD (G.P.M.) 10+
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 30'		DURING YIELD TEST (feet)		Depth of Completed Well in feet below Land surface: 170'
SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
0	10	Drilling in overburden clay and boulders	
		Hit rock at 10 feet	
10	30	Drilling in rock, set casing, grouted.	
30	170	Drilling in rock granite	

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED 12/19/83	DATE OF REPORT 1/3/84	WELL DRILLER (Signature) 
---------------------------------	--------------------------	--