332

WELL COMPLETION REPORT
3/71

BREWSTER

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

41 22 44 73 34 53

P1143

OWNER	NAME Harold Smith	ADDRESS Elmwood Drive, Brewster, NY
LOCATION OF WELL	(No. & Street) Rte 121	(Town) Brewster, NY (Lot Number) Lot #13
PROPOSED USE OF WELL	[X] DOMESTIC [ ] BUSINESS ESTABLISHMENT [ ] FARM [ ] TEST WELL [ ] PUBLIC SUPPLY [ ] INDUSTRIAL [ ] AIR CONDITIONING [ ] OTHER (Specify) 535 L	
DRILLING EQUIPMENT	[X] ROTARY [ ] COMPRESSED AIR PERCUSSION [ ] CABLE PERCUSSION [ ] OTHER (Specify)	
CASING DETAILS	LENGTH (feet) 105' DIAMETER (inches) 6 WEIGHT PER FOOT 19 lbs. [X] THREADED [ ] WELDED DRIVE SHOE [X] YES [ ] NO WAS CASING GROUTED? [X] YES [ ] NO	
YIELD TEST	[ ] BAILED [X] PUMPED [ ] COMPRESSED AIR HOURS 6 G.P.M. 5 YIELD (G.P.M.) 5	
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet) 5' DURING YIELD TEST (feet) Depth of Completed Well in feet below Land surface: 320	
SCREEN DETAILS	MAKE LENGTH OPEN TO AQUIFER (feet) SLOT SIZE DIAMETER (inches) IF GRAVEL PACKED: Diameter of well including gravel pack (inches): GRAVEL SIZE (inches) FROM (feet) TO (feet)	

DEPTH FROM LAND SURFACE FEET	to FEET	FORMATION DESCRIPTION
0	95	Drilling in overburden clay & boulders
		Hit rock at 95 feet
95	105	Drilling in rock-set casing grouted
105	320	Drilling in rock-schist

Sketch exact location of well with distances, to at least two permanent landmarks.

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
3/2/79	8/16/79	Malcolm T. Beard Jr.