

BREWSTER

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION


P1146

41 25 15 73 32 58

OWNER	NAME William Busch		ADDRESS Box 41 Patterson, N.Y.	
LOCATION OF WELL	(No. & Street) 1319 Shore Dr. Brewster, N.Y.		(Town)	(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify) 420 S
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)
CASING DETAILS	LENGTH (feet) 95'	DIAMETER (Inches) 7" OD	WEIGHT PER FOOT 23 lb	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED
				DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
				WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS ONE
				G.P.M. 15
				YIELD (G.P.M.) 15
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 25'		DURING YIELD TEST (feet)	
			Depth of Completed Well in feet below Land surface: 140'	
SCREEN DETAILS	MAKE N.A.			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (Inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (Inches):
				GRAVEL SIZE (Inches) FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION
FEET	to FEET	
0	85'	Hardpan
85'	140'	Ledge rock

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature) PROP., BOYD ARTESIAN WELL CO.
---------------------	----------------	---