

5410
WELL COMPLETION REPORT
3/71

BREWSTER

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

41 24 56 73 36 36

P1151

OWNER	NAME Biondi		ADDRESS 40 BENEDICT ASSOC. LAKEVIEW DR. No. SALEM, NY	
LOCATION OF WELL	(No. & Street) Tonetta LAKE Way		(Town) Brewster, N.Y.	(Lot Number) 13, 16, 18
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify) 420 S
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)
	CASING DETAILS	LENGTH (feet) 131	DIAMETER (Inches) 6	WEIGHT PER FOOT
YIELD TEST	<input type="checkbox"/> BAILED	<input checked="" type="checkbox"/> PUMPED	<input type="checkbox"/> COMPRESSED AIR	HOURS 6
	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 10	DURING YIELD TEST (feet) 180	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	G.P.M. 50
WATER LEVEL	Depth of Completed Well in feet below Land surface: 185		YIELD (G.P.M.) 50	
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (Inches)	IF GRAVEL PACKED	Diameter of well including gravel pack (Inches):

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
0	118'	gravel + clay	Please See Site Plan
118'	185'	granite + sandstone	



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED: 12/18/80
DATE OF REPORT: 1/10/81
WELL DRILLER (Signature): Ragg Andy Well Drillers, Bruce W. Ragg