Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

541 BREWSTER

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1152

41 23 16 73 36 37

OWNER	NAME: TIMOTHY PLUMMER		ADDRESS: 13 Washington Place, No. White Plain, NY	
LOCATION OF WELL	(No. & Street): Turk Hill Road		(Town): Brewster, New York	(Lot Number): 2
PROPOSED USE OF WELL	[X] DOMESTIC; [ ] BUSINESS ESTABLISHMENT; [ ] PUBLIC SUPPLY; [ ] INDUSTRIAL		[ ] FARM; [ ] AIR CONDITIONING	[ ] TEST WELL; [ ] OTHER (Specify) SSD S
DRILLING EQUIPMENT	[ ] ROTARY; [X] COMPRESSED AIR PERCUSSION		[ ] CABLE PERCUSSION	[ ] OTHER (Specify)
CASING DETAILS	LENGTH (feet): 114	DIAMETER (inches): 6	WEIGHT PER FOOT: 19	[X] THREADED [ ] WELDED; DRIVE SHOE [X] YES [ ] NO; WAS CASING GROUTED? [X] YES [ ] NO
YIELD TEST	[ ] BAILED; [ ] PUMPED; [X] COMPRESSED AIR	HOURS: 4	G.P.M.: 10	YIELD (G.P.M.): 10
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet): 35	DURING YIELD TEST (feet): 500	Depth of Completed Well in feet below land surface: 500	
SCREEN DETAILS	MAKE:			LENGTH OPEN TO AQUIFER (feet):
	SLOT SIZE:	DIAMETER (inches):	IF GRAVEL PACKED: Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches): FROM (feet): TO (feet):

DEPTH FROM LAND SURFACE FEET	TO FEET	FORMATION DESCRIPTION
0	102	Grey hardpan.
102	500	Medium to hard grey granite.

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (signature)
10/26/83	10/24/83	Robert M. Mills