

41 24 13 73 41 16

C103

LAKE CARMEL

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P 906

OWNER	NAME WALTER GALBRAITH		ADDRESS CRANE ROAD, CARMEL, NEW YORK			
LOCATION OF WELL	(No. & Street) DYKEMAN ROAD, CARMEL, NEW YORK		(Town)		(Lot Number)	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL		
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)	SSS J	
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)		
	CASING DETAILS	LENGTH (feet) 131 ft.	DIAMETER (inches) six	WEIGHT PER FOOT 19	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS five	G.P.M. forty	YIELD (G.P.M.) 40 GPM
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 20 ft.		DURING YIELD TEST (feet)		Depth of Completed Well in feet below Land surface: 165 ft.	
SCREEN DETAILS	MAKE					LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
0	110	Drilling in overburden - clay and boulders Hit solid rock at 110 ft.	
110	131	Drilling in rock - setting casing - grouted	
131	165	Drilling in rock - granite	
If yield was tested at different depths during drilling, list below			
FEET		GALLONS PER MINUTE	

DATE WELL COMPLETED Aug 8, 73	DATE OF REPORT Oct 11, 73	WELL DRILLER (Signature) P. F. BEAL & SONS, INC. <i>Michael T. Beal</i>
----------------------------------	------------------------------	---