WELL COMPLETION REPORT
3/71

C114

041 21 47' 73 46 27
Hohegan

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P912

OWNER	NAME: George Papania		ADDRESS:	
LOCATION OF WELL	(No. & Street): 6 N,	Mahopac (Town)	New York	(Lot Number): 3
PROPOSED USE OF WELL	☒ DOMESTIC	☐ BUSINESS ESTABLISHMENT	☐ FARM	☐ TEST WELL ~~X~~ 520' C
	☐ PUBLIC SUPPLY	☐ INDUSTRIAL	☐ AIR CONDITIONING	☐ OTHER (Specify)
DRILLING EQUIPMENT	☐ ROTARY	☒ COMPRESSED AIR PERCUSSION	☐ CABLE PERCUSSION	☐ OTHER (Specify)
CASING DETAILS	LENGTH (feet): 160'	DIAMETER (inches): 6"	WEIGHT PER FOOT: 19	☒ THREADED ☐ WELDED; DRIVE SHOE ☒ YES ☐ NO; WAS CASING CEMENTED? ☒ YES ☐ NO
YIELD TEST	☐ BAILED	☐ PUMPED	☒ COMPRESSED AIR	HOURS: 4; G.P.M.: 8; YIELD (G.P.M.): 8
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet): 14'	DURING YIELD TEST (feet): 298	Depth of Completed Well in feet below Land surface: 300'	
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED: Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE FEET	TO FEET	FORMATION DESCRIPTION
0	150	Soil
150	300	Bedrock

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

6/15/75 — DATE WELL COMPLETED | DATE OF REPORT | WELL DRILLER (Signature): [illegible]