

~~Hohegan~~ (Delete from Hohegan)
LAKE CARMEL

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.


REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P913

OWNER	NAME EQUITY BUILDERS		ADDRESS LAKE MAHOPAC	
LOCATION OF WELL	(No. & Street) FAIRMONT		(Town) 41 23 08	(Lot Number) 73 43 23
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify) 600+ \$ 740 S
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input checked="" type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)
CASING DETAILS	LENGTH (feet) 148	DIAMETER (Inches) 6	WEIGHT PER FOOT 17	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
	<input checked="" type="checkbox"/> THREADED	<input type="checkbox"/> WELDED	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
YIELD TEST	<input checked="" type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input type="checkbox"/> COMPRESSED AIR	HOURS 6 G.P.M. 5 YIELD (G.P.M.) 5
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 14		DURING YIELD TEST (feet) 100	
	MAKE			Depth of Completed Well in feet below Land surface: 178
SCREEN DETAILS	MAKE	LENGTH OPEN TO AQUIFER (feet)		
	SLOT SIZE	DIAMETER (Inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (Inches):
		GRAVEL SIZE (Inches)	FROM (feet)	TO (feet)

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION
FEET	to FEET	
0	1	TAP SOIL
1	4	LOAM
4	138	GRAY CLAY
138	178	BROWN MICA SCHIST

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED 5/26/85	DATE OF REPORT 6/29/85	WELL DRILLER (Signature) <i>[Signature]</i>
---------------------------------------	----------------------------------	--