

C121

41 21 28

73 42 47

CRISTON FALLS

WELL COMPLETION REPORT  
3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH  
Division of Environmental Health Services  
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P918

41 21 28 73 42 47

OWNER	NAME Dr. Lawrence J. Melnick		ADDRESS Pine Valley Rd Mahopac	
LOCATION OF WELL	(No. & Street) Lot 1 Cossicks Acres		(Town) Carmel	(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input checked="" type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)
	LENGTH (feet) 50' 4"	DIAMETER (Inches) 6	WEIGHT PER FOOT 19.45	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
CASING DETAILS	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED		WAS CASING GROUTED? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
YIELD TEST	<input checked="" type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input type="checkbox"/> COMPRESSED AIR	HOURS 3
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 40		DURING YIELD TEST (feet) 200	
	MAKE			LENGTH OPEN TO AQUIFER (feet) 402
SCREEN DETAILS	SLOT SIZE	DIAMETER (Inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (Inches):
	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	

625 5

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
FEET	to FEET		
0	30	loam + cobbles	
30	50'	soft rock	
50	402	black + white granite	

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE
136'	1
260'	1 1/3
340	1 1/3
	1

DATE WELL COMPLETED Mar 21, 1973	DATE OF REPORT Mar 16, 1973	WELL DRILLER (Signature) Louis Melanchuk + Son Inc.
-------------------------------------	--------------------------------	--