LAKE CARMEL

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

C127

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P921

41 26 08 73 40 56

OWNER	NAME: Aderville Plourde		ADDRESS: Buckshollow Road, Mahopac, NY	
LOCATION OF WELL	(No. & Street): Rolling Green		(Town): Mahopac, New York	(Lot Number):
PROPOSED USE OF WELL	[X] DOMESTIC	[ ] BUSINESS ESTABLISHMENT	[ ] FARM	[ ] TEST WELL
	[ ] PUBLIC SUPPLY	[ ] INDUSTRIAL	[ ] AIR CONDITIONING	[ ] OTHER (Specify)
DRILLING EQUIPMENT	[ ] ROTARY	[X] COMPRESSED AIR PERCUSSION	[ ] CABLE PERCUSSION	[ ] OTHER (Specify)

540 S

CASING DETAILS	LENGTH (feet)	DIAMETER (inches)	WEIGHT PER FOOT	[X] THREADED [ ] WELDED	DRIVE SHOE [X] YES [ ] NO	WAS CASING GROUTED? [X] YES [ ] NO
	31	6	17			

YIELD TEST	[ ] BAILED	[ ] PUMPED	[X] COMPRESSED AIR	HOURS	G.P.M.	YIELD (G.P.M.)
				4	14	14

WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet)	DURING YIELD TEST (feet)	Depth of Completed Well in feet below land surface:
	25	345	345

SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) FROM (feet)	TO (feet)

DEPTH FROM LAND SURFACE FEET	TO FEET	FORMATION DESCRIPTION
0	1½	Sandy Clay
1½	20	Medium-hard bedrock
20	345	Hard black & white granite

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (signature)
6/15/83	7/8/83	Robert M Mill, President-MILL DRILLING, INC.