WELL COMPLETION REPORT
3/71

C128 LAKE CARMEL

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P922
41 2601 73 40 04

OWNER	NAME: Mr. Omer Bacovic		ADDRESS: 2075 E. 16th St. Brooklyn, NY	
LOCATION OF WELL	(No. & Street): Glenn Drive, Carmel, NY		(Town)	(Lot Number)
PROPOSED USE OF WELL	[X] DOMESTIC	[ ] BUSINESS ESTABLISHMENT	[ ] FARM	[ ] TEST WELL
	[ ] PUBLIC SUPPLY	[ ] INDUSTRIAL	[ ] AIR CONDITIONING	[ ] OTHER (Specify) 530 L
DRILLING EQUIPMENT	[X] ROTARY	[ ] COMPRESSED AIR PERCUSSION	[ ] CABLE PERCUSSION	[ ] OTHER (Specify)

CASING DETAILS	LENGTH (feet)	DIAMETER (inches)	WEIGHT PER FOOT		DRIVE SHOE	WAS CASING GROUTED?
	40'	6"	19 lbs.	[X] THREADED [ ] WELDED	[X] YES [ ] NO	[X] YES [ ] NO

YIELD TEST				HOURS	G.P.M.	YIELD (G.P.M.)
	[ ] BAILED	[X] PUMPED	[ ] COMPRESSED AIR	6	20	20

WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet)	DURING YIELD TEST (feet)	Depth of Completed Well in feet below Land surface:
	36'		360'

SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet) / TO (feet)

DEPTH FROM LAND SURFACE FEET	to FEET	FORMATION DESCRIPTION
0	15	Drilling in overburden clay and boulders
		Hit rock at 15 feet
15	40	Drilling in rock, set casing and grouted
40	360	Drilling in granite

Sketch exact location of well with distances, to at least two permanent landmarks.

RECEIVED
NOV 7 1983
PUTNAM COUNTY
DEPT. OF HEALTH

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
10/21/83	11/1/83	