

WELL COMPLETION REPORT

3/71

138

CROTON FALLS

PUTN. COUNTY DEPARTMENT OF HEALTH
 Division of Environmental Health Services
 COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

41 21 03 73 43 10

P977

OWNER	NAME Richard Casciato		ADDRESS HELLMAN LAVE + Brookside RD. Mahopac, NY			
LOCATION OF WELL	(No. & Street) HELLMAN LAVE + Brookside RD.		(Town) Carmel		(Lot Number)	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL	650 H	
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)		
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)		
CASING DETAILS	LENGTH (feet) 68	DIAMETER (Inches) 6	WEIGHT PER FOOT 19	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 2	G.P.M. 20	YIELD (G.P.M.) 20
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) overflow		DURING YIELD TEST (feet) total drawdown		Depth of Completed Well in feet below Land surface: 140	
SCREEN DETAILS	MAKE					LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (Inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (Inches):	GRAVEL SIZE (Inches) FROM (feet) TO (feet)	

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION
FEET	to FEET	
0	50	clay
50	140	ledge

Sketch exact location of well with distances, to at least two permanent landmarks.

RECEIVED
 MAR 17 1982
 PUTNAM COUNTY
 DEPT. OF HEALTH

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED 11/6/81	DATE OF REPORT 3/4/82	WELL DRILLER (Signature) <i>Walter Van Buren</i>
--------------------------------	--------------------------	---