

WELL COMPLETION REPORT

This report is to be completed by well driller and submitted to Health Department, together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality, before certificate of construction compliance is issued.

Well construction to be in accordance with Bulletin SD-62
"RULES & REGULATIONS RELATING TO INDIVIDUAL WATER SUPPLIES"

640 H

LOCATION: MUNICIPALITY CARMEL SECTION 2 BLOCK _____ LOT 27
 WELL OWNER: CARMEL HILLS ESTATES CARMEL N.Y.
 Name Street Address City and Town
 WELL DRILLER: J. TORLISH SONS MAPLE AVE ARMONK N.Y.
 Name Street Address City and Town

CASING DETAILS		YIELD TEST		WATER LEVEL		SCREEN DETAILS	
Length:	25 Feet	Bailed	6 Hours	Static:	48 Feet	Make:	
Diameter:	6 Inches	Yield:	5 G.P.M.	When Bailed	325 Feet	Length	Slot Size
Kind:	Steel			or Pumped		Diameter	In.

TOTAL DEPTH OF WELL 345 FEET

WELL LOG

Depth From Ground Surface	Give description of formations penetrated, such as: peat, silt, sand, gravel, clay, hardpan, shale, sandstone, granite, etc. Include size of gravel (diameter) and sand (fine, medium, coarse), color of material, structure (Loose, packed, cemented, soft, hard). For example: 0 ft. to 27 ft. fine, packed, yellow sand; 27 ft. to 134 ft. gray granite.	
0 Ft. to 14 Ft.	HARD PAN	1
14 Ft. to 185 Ft.	BLACK ROCK	2
185 Ft. to 240 Ft.	SAINT PETER GRANITE	3
240 Ft. to 310 Ft.	GRAY GRANITE	4
310 Ft. to 345 Ft.	BLACK ROCK	5
Ft. to Ft.		
Ft. to Ft.		
Ft. to Ft.		

Date Well Was Completed Aug 18, 1971 Date of Report Sept 3, 1971
 Well Driller James Torlish Signature