

OSCAWANA

WELL COMPLETION REPORT

3/71

4168

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK


This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P943

OWNER	NAME Honkola Custom Builders		ADDRESS Bullet Hole Road, Mahopac, NY	
LOCATION OF WELL	(No. & Street) Lake Drive, Lake Casse		(Town) Mahopac	(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL 565 F
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)
CASING DETAILS	LENGTH (feet) 60 1/2	DIAMETER (inches) 6	WEIGHT PER FOOT 19	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED
	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 4
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 30		DURING YIELD TEST (feet) 260	
	G.P.M. 30			YIELD (G.P.M.) 30
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):

DEPTH FROM LAND SURFACE FEET TO FEET	FORMATION DESCRIPTION
0 55	Hardpan.
55 260	Medium hard granite.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED 8-5-76	DATE OF REPORT 8-9-76	WELL DRILLER (Signature) <i>[Signature]</i> , President MILL DRILLING, INC.
-------------------------------	--------------------------	---