OSCAWANA

WELL COMPLETION REPORT
3/71

C 8/71

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING · CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P944

OWNER	NAME: MONKOLA CUSTOM BUILDERS, INC.	ADDRESS: P.O. Box 59, Mahopac, New York		
LOCATION OF WELL	(No. & Street): Lakeview Drive	(Town): Mahopac, New York	(Lot Number):	
PROPOSED USE OF WELL	[X] DOMESTIC; [ ] BUSINESS ESTABLISHMENT; [ ] FARM; [ ] TEST WELL; 590 F	[ ] PUBLIC SUPPLY; [ ] INDUSTRIAL; [ ] AIR CONDITIONING; [ ] OTHER (Specify)		
DRILLING EQUIPMENT	[ ] ROTARY; [X] COMPRESSED AIR PERCUSSION; [ ] CABLE PERCUSSION; [ ] OTHER (Specify)			
CASING DETAILS	LENGTH (feet): 75	DIAMETER (inches): 6	WEIGHT PER FOOT: 17	[X] THREADED [ ] WELDED; DRIVE SHOE [X] YES [ ] NO; WAS CASING GROUTED? [X] YES [ ] NO
YIELD TEST	[ ] BAILED; [ ] PUMPED; [X] COMPRESSED AIR	HOURS: 4	G.P.M.: 5	YIELD (G.P.M.): 5
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet): 30	DURING YIELD TEST (feet): 500	Depth of Completed Well in feet below Land surface: 500	
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):
	GRAVEL SIZE (inches)	FROM (feet)	TO (feet)	

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION
0	70	Hardpan.
70	500	Hard gray granite.

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
9/25/73	9/31/73	Robert M Mill, President — MILL DRILLING, INC.