

C18

WELL COMPLETION REPORT
3/71

LAKE CARMEL

41 23 19 73 44 05

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK


This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P 948

OWNER	NAME Robert Benz		ADDRESS North Lake Boulevard			
LOCATION OF WELL	(No. & Street) North Lake Boulevard		(Town) Mahopac		(Lot Number)	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL	680 5	
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)		
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)		
CASING DETAILS	LENGTH (feet) 32	DIAMETER (inches) 6	WEIGHT PER FOOT 17	<input checked="" type="checkbox"/> THREADED	<input type="checkbox"/> WELDED	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
						WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 4	G.P.M. 8 1/2	YIELD (G.P.M.) 8 1/2
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 6"		DURING YIELD TEST (feet) 240		Depth of Completed Well in feet below Land surface: 240	
	MAKE					LENGTH OPEN TO AQUIFER (feet)
SCREEN DETAILS	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION
0	3	Soft clay.
3	5	Soft clay with boulders.
5	21	Hardpan and boulders.
21	23	Weathered ledge.
23	32	Hard granite (set casing).
32	240	Hard gray granite.
If yield was tested at different depths during drilling, list below		
FEET	GALLONS PER MINUTE	
200	5	
220	6 1/2	
240	6 1/2	



DATE WELL COMPLETED May 9, 1979	DATE OF REPORT 5-15-79	WELL DRILLER (Signature) <i>[Signature]</i>	<i>[Signature]</i> President
PUTNAM AVE, BREWSTER HILL DRILLING, INC.			