

WELL COMPLETION REPORT

3/71

1188

CLUTON FALLS

PUTNAM COUNTY DEPARTMENT OF HEALTH

Division of Environmental Health Services

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P952

41 21 09

93 43 09

OWNER	NAME: <i>J.R. Enterprises</i> ADDRESS: <i>Maloga N.Y.</i>	
LOCATION OF WELL	<i>Lawell Street; Maloga N.Y. 12541</i>	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC <input type="checkbox"/> BUSINESS ESTABLISHMENT <input type="checkbox"/> FARM <input type="checkbox"/> TEST WELL <input type="checkbox"/> PUBLIC SUPPLY <input type="checkbox"/> INDUSTRIAL <input type="checkbox"/> AIR CONDITIONING <input type="checkbox"/> OTHER (Specify)	
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY <input type="checkbox"/> COMPRESSED AIR PERCUSSION <input type="checkbox"/> CABLE PERCUSSION <input type="checkbox"/> OTHER (Specify)	
CASING DETAILS	LENGTH (feet): <i>22'</i> DIAMETER (inches): <i>6"</i> WEIGHT PER FOOT: <i>17</i>	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED DRIVE SHOE: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED <input type="checkbox"/> PUMPED <input checked="" type="checkbox"/> COMPRESSED AIR	HOURS: <i>7+</i> G.P.M.: <i>5</i> YIELD (G.P.M.): <i>5</i>
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet): DURING YIELD TEST (feet):	Depth of Completed Well in feet below land surface: <i>340'</i>
SCREEN DETAILS	MAKE: SLOT SIZE: DIAMETER (inches): IF GRAVEL PACKED:	LENGTH OPEN TO AQUIFER (feet): GRAVEL SIZE (inches) FROM (feet) TO (feet):

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
FEET	TO FEET		
<i>1'</i>	<i>12'</i>	<i>hardpan overburden</i>	
<i>12'</i>	<i>340'</i>	<i>bedrock granite</i>	

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED: <i>4/1/85</i>	DATE OF REPORT: <i>!</i>	WELL DRILLER (Signature): <i>N. Anderson</i>
------------------------------------	--------------------------	--