371

Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

C199 REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION Hdregan

OWNER	NAME: BYRWA, Arthur	ADDRESS: 170 Hawthorne Ave, Yonkers, NY P 961
LOCATION OF WELL	(No. & Street): Rolling Green	(Town): Mahopac, NY (Lot Number):

PROPOSED USE OF WELL: [X] DOMESTIC [ ] BUSINESS ESTABLISHMENT [ ] FARM [ ] TEST WELL 800 S [ ] PUBLIC SUPPLY [ ] INDUSTRIAL [ ] AIR CONDITIONING [ ] OTHER (Specify)

DRILLING EQUIPMENT: [ ] ROTARY [X] COMPRESSED AIR PERCUSSION [ ] CABLE PERCUSSION [ ] OTHER (Specify)

CASING DETAILS	LENGTH (feet)	DIAMETER (inches)	WEIGHT PER FOOT		DRIVE SHOE	WAS CASING GROUTED
	117½	6	19	[X] THREADED [ ] WELDED	[X] YES [ ] NO	[ ] YES [X] NO

YIELD TEST				HOURS	G.P.M.	YIELD (G.P.M.)
	[ ] BAILED	[ ] PUMPED	[X] COMPRESSED AIR	4	1½	1½

WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet)	DURING YIELD TEST (feet)	Depth of Completed Well In feet below land surface:
	58	800	800

SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) FROM (feet)	TO (feet)

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION
0	105	Grey Hardpan & Boulders
105	800	Hard Granite

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE
500	3/4
800	1-1/2

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER Signature
10/6/83	10/21/83	Robert M. Mill, President