C207 Division of Environmental Sanitation Mohegan

P 967

WELL COMPLETION REPORT

This report is to be completed by well driller and submitted to Health Department, together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality, before certificate of construction compliance is issued.

800 S

Well construction to be in accordance with Bulletin SD-62
"RULES & REGULATIONS RELATING TO INDIVIDUAL WATER SUPPLIES"

LOCATION: MUNICIPALITY CARMEL ~~SECTION~~ T.M. 141 BLOCK 12 LOT 13 & 14

WELL OWNER: JOHN LOBUE (Name) ROLLING GREENS (Street Address) MAHOPAC (City and Town)

WELL DRILLER: WRAGG BROS. WELL DRILLING CORP. (Name) ROUTE 7, WILTON, CONN, 06897 (Street Address, City and Town)

CASING DETAILS	YIELD TEST	WATER LEVEL (measure from land surface)	SCREEN DETAILS
Length: 81 Feet	___ Bailed or X Pumped 6 Hours	Static: 80 Feet	Make: NONE
Diameter: 6 Inches	Yield: 3 G.P.M.	When Bailed or Pumped 605 Feet	Length NONE Ft. Slot Size
Kind: STEEL			Diameter NONE In.

TOTAL DEPTH OF WELL 605 FEET

WELL LOG

Depth From Ground Surface	Give description of formations penetrated, such as: peat, silt, sand, gravel, clay, hardpan, shale, sandstone, granite, etc. Include size of gravel (diamet and sand (fine, medium, coarse), color of material, structure (Loose, packed, cemented, soft, hard). For example: 0 ft. to 27 ft. fine, packed, yellow sand 27 ft. to 134 ft. gray granite.
0 Ft. to 81 Ft.	CLAY.
81 Ft. to 605 Ft.	LIGHT GRANITE AND QUARTZ.
Ft. to Ft.	
Ft. to Ft.	
Ft. to Ft.	
Ft. to Ft.	
Ft. to Ft.	
Ft. to Ft.	

Date Well Was Completed 9/12/77 Date of Report 11/18/77

Well Driller Bruce W. Wragg
Signature