WELL COMPLETION REPORT
3/71

C211

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliancy is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

OSCAWANA
P 970

OWNER	NAME: Bellesite Homes	ADDRESS: c/o Roger Bisch, Old Bullet Hole Rd., Mahopac
LOCATION OF WELL	(No. & Street): Old Bullet Hole Rd.,	(Town): Mahopac, NY (Lot Number):
PROPOSED USE OF WELL	[X] DOMESTIC; [ ] BUSINESS ESTABLISHMENT; [ ] FARM; [ ] TEST WELL; [ ] PUBLIC SUPPLY; [ ] INDUSTRIAL; [ ] AIR CONDITIONING; [ ] OTHER (Specify)	660 S
DRILLING EQUIPMENT	[X] ROTARY; [ ] COMPRESSED AIR PERCUSSION; [ ] CABLE PERCUSSION; [ ] OTHER (Specify)	
CASING DETAILS	LENGTH (feet): 30; DIAMETER (inches): 6; WEIGHT PER FOOT: 19 lbs.; [X] THREADED [ ] WELDED; GRAVE SHOE [X] YES [ ] NO; WAS CASING GROUTED [X] YES [ ] NO	
YIELD TEST	[ ] BAILED; [X] PUMPED; [ ] COMPRESSED AIR; HOURS: 6; G.P.M.: 7; YIELD (G.P.M.): 7	
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet): 32'; DURING YIELD TEST (feet):	Depth of Completed Well in feet below land surface: 260'
SCREEN DETAILS	MAKE: ; LENGTH OPEN TO AQUIFER (feet): ; SLOT SIZE: ; DIAMETER (inches): ; IF GRAVEL PACKED: Diameter of well including gravel pack (inches): ; GRAVEL SIZE (inches): ; FROM (feet): ; TO (feet):	

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION
0	1	Drilling in overburde clay & boulders
		Hit rock at 1 foot
1	30	Drilling in rock-set casing grouted
30	260	Drilling in rock-schi

Sketch exact location of well with distances, to at least two permanent landmarks.

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER
10/23/78	12/13/78	