

LAKE CARMEL 41 23 18 73 42 51

WELL COMPLETION REPORT

PUTNAM COUNTY DEPARTMENT OF HEALTH

3/71

C215 ADD TO Lake Carmel

Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION


P 973

OWNER	NAME EMIL & PHYLLIS LUCARINI <small>(No. & Street)</small>		ADDRESS OVERLOOK DR. MANTOPAC TAX MAP 50-11-SECT 1 <small>(Town)</small> <small>(Lot Number)</small>	
LOCATION OF WELL	OVERLOOK DRIVE -			
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)
CASING DETAILS	LENGTH (feet) 60	DIAMETER (Inches) 6	WEIGHT PER FOOT 17	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED
				DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 2
				G.P.M. 10
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 60'		DURING YIELD TEST (feet) Bottom	
			Depth of Completed Well in feet below Land surface: 225	
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (Inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (Inches):
				GRAVEL SIZE (Inches) FROM (feet) TO (feet)

735, H

DEPTH FROM LAND SURFACE FEET to FEET	FORMATION DESCRIPTION	
0 - 15	GRAVEL & Boulders	
16 - 47	HARD PAN some cobbles	
48 - 59	Solid Rock	
60 - 148	Solid Rock	
149 - 153	Some WATER	
154 - 196	Solid Rock	
197 - 200	WATER	
201 - 225	Solid Rock	

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE
160	3
205	10

DATE WELL COMPLETED 7/13/84	DATE OF REPORT 8/7/84	WELL DRILLER (Signature) Frank Salmeri
--------------------------------	--------------------------	---